

SDM230 Series

Single Phase Two Wire Multifunction Din Rail Meter



User Manual V1.6

Warnings

Important Safety Information is contained in the Maintenance section. Familiarize yourself with this information before attempting installation or other procedures.

Risk of Danger: These instructions contain important safety information. Read them before starting installation or servicing of the equipment.

Caution: Risk of Electric Shock

1. Introduction

This document provides operating, maintenance and installation instructions of SDM230 series made by Eastron Electronic Co., Ltd. The SDM230 series measure and display the characteristics of single phase two wire (1p2w) network. The SDM230 series covers 5 models: SDM230-Modbus, SDM230-Pulse, SDM230-Mbus, SDM230-2T and SDM230-Std.

The bi-directional measurement makes the meter suitable for active and reactive energy and power monitoring applications, and also perfect for solar PV measurements. With RS485 Modbus and M-bus port, the meter is easy to remote communication with other AMR/SCADA systems.

Model	Measurements	Communication	Pulse Outputs	Multi Tariffs
SDM230-Modbus	U, I, P, Q, S, PF, Hz, Dmd, kWh, kVAh, Import, Export	RS485 Modbus	1: configurable 2: 1000imp/kwh	NO
SDM230-Mbus	U, I, P, Q, S, PF, Hz, Dmd, kWh, kVAh, Import, Export	M-bus EN13757-3	1: configurable 2: 1000imp/kwh	NO
SDM230-Pulse	U, I, P, Q, S, PF, Hz, Dmd, kWh, kVAh, Import, Export	NO	1: configurable 2: 1000imp/kwh	NO
SDM230-2T	U, I, P, Q, S, PF, Hz, Dmd, kWh, kVAh, Import, Export	RS485 Modbus	1: configurable 2: 1000imp/kwh	2 Tariffs (time relay)
SDM230-Std	kWh, kVAh, Import, Export	RS485 Modbus	1: configurable 2: 1000imp/kwh	NO

1.1 Key Characteristics

- Bi-directional measure and display
- Multi-function measurements
- Two Pulse outputs
- RS485 Modbus / M-bus
- 100A direct connection
- Two module size (35mm)
- Password protected set-up
- Backlighted LCD
- 2 tariff dual power source

1.2 Pulse output

The meter provides two pulse outputs. Both pulse outputs are passive type.

Pulse output 1 can be set to generate pulses to represent total / import/export kWh or kVAh.

The pulse constant can be set to generate 1 pulse per: 0.001/0.01/0.1/kWh/kVAh (default is 0.001 export kWh).

Pulse width: 200/100/60ms

Pulse output 2 is non-configurable. It is fixed up with active kWh (Imp). The constant is 1000imp/kWh.

1.3 RS485 Serial – Modbus RTU

RS485 serial port with Modbus RTU protocol to provide a means of remotely monitoring and controlling the Unit. Set-up screens are provided for setting up the RS485 port.

1.4 Mbus for SDM230-Mbus

This unit has an M-BUS serial port with M-BUS protocol to provide a means of remotely monitoring and controlling the unit set-up screens are provided for setting up the M-bus port.

1.5 2T by time relay for SDM230-2T

The unit has a time relay inside which can monitor if there is external 230V signal input. If there is 230V signal input, the meter switches Tariff 2 measurement, otherwise it will measure as Tariff 1.

2. Operation

2.1 LCD Display



NO.	Descriptions
1	7 digits used to display measured values
2	Total value
3	Tariff information
4	Import information, Export information
5	Max. Demand for Power or Current.
6	Pulse output 1and Pulse output2
7	Measurement units
8	PF = power factor Hz = frequency
9	Bar display of Power
10	Communication indicator
13	Lock symbol

2.2 Initialization Display

SDM230-Modbus	ΣT8IMPEXPMD1JLJL2 888.88.88 PF Hz MkVAh MkWhI C L L	All display segments light up, display check.
SDM230-Mbus	04 0 10 1	Software version (please check the real software version on the product as the final).
SDM230-Pulse	Add 00 1	Modbus ID or Mbus Primary Address
SDM230-2T	I dH0000	Mbus Secondary Address (High) (for SDM230-Mbus only)
SDM230-Std	I dL0000 1	Mbus Secondary Address (Low) (for SDM230-Mbus only)
	bd 2400	Baud rate.
	Σ 000 70.00 kWh	Total kWh.

2.3 Scroll display by Buttons

After initialization and self-checking program, the meter display the measured values. The default page is total kWh. If the user wants to check other information, he needs to press the scroll button on the front panel.

The display order by scroll button :

*For SDM230-Modbus:

Total kWh → Import kWh → Export kWh → Resettable kWh → Total kVAh → Import kVAh → Export kVAh → Resettable kVAh → Max. Power Demand → Voltage → Current → W → Var → VA → Power Factor → Frequency → Pulse Constant → Modbus ID → Baud Rate → Continuous Running Time
Display No:1,4~7,10~24.

*For SDM230-Pulse:

Total kWh → Import kWh → Export kWh → Resettable kWh → Total kVAh → Import kVAh → Export kVAh → Resettable kVAh → Max. Power Demand → Voltage → Current → W → Var → VA → Power Factor → Frequency → Pulse Constant → Modbus ID → Baud Rate → Continuous Running Time
Display No:1,4~7,10~21.

*For SDM230-2T:

Total kWh → T1 total kWh → T2 total kWh → Import kWh → Export kWh → resettable kWh → Total kVAh → T1 total kVAh → Import kVAh → Export kVAh → resettable kVAh → Max. Power Demand → Voltage → Current → W → Var → VA → Power Factor → Frequency → Pulse Constant → Modbus ID → Baud Rate → Continuous Running Time
Display No: 1~24.

*For SDM230-Mbus:

Total kWh → Import kWh → Export kWh → Resettable kWh → Total kVAh → Import kVAh → Export kVAh → Resettable kVAh → Max. Power Demand → Voltage → Current → W → Var → VA → Power Factor → Frequency → Pulse Constant → Modbus ID → Baud Rate → Continuous Running Time
Display No:1,4~7,10~24.

*For SDM230-Std:

Total kWh → Import kWh → Export kWh → Resettable kWh → Total kVAh → Import kVAh → Export kVAh → Resettable kVAh → Pulse Constant → Modbus ID → Baud Rate → Continuous Running Time
Display No:1,4~7,10~12, 21~24.

13	Σ MD 6938 W	Max. power demand Example: 6938W
14	2298 V	Voltage Example: 229.8V
15	30.156 A	Current Example: 30.156A
16	4700 W	Active power Example: 4700W
17	1030 Var	Reactive power Example: 1030Var
18	4811 VA	Apparent power Example: 4811VA
19	1.000 PF	Power factor Example: 1.000
20	49.99 Hz	Frequency Example: 49.99Hz
21	c5E 1000	Pulse 2 constant Example: 1000
22	Add 00 1	Modbus address Example: 001 Mbus primary address Example: 001
22-1	I dH0000	High and Low bit of MBUS Secondary address (Default 00 00 01) Example: if the Secondary address high bit is 0000, low bit is 0001, that means the integral Secondary address is 00 00 00 01 (for SDM230-Mbus only)
23	bd 9600	Baud rate Example: 9600
24	10.0h Σ	Continuous running time (since last time reset)

2.4 Set-up Mode

To get into Set-up Mode, the user needs to press the "Enter" button for 3 seconds.

Good	The setting is done correctly
Err	The entering information is wrong. The operation fails.

1	PAS0000	Password To get into Set-up mode, it asks a password confirmation. Default password: 1000
2	Add 001	Address For Modbus: Default ID is 001 Range: 001~247 For Mbus: Primary address ID Default ID is 001 Range:001~250
2-1	Add 001	Press the "Enter" button, the first digit flash. Press the "Scroll" button to change the value. After choosing the new address value, the user needs to press the "Enter" button to confirm the setting.
2-2	I dh0000	High bit of Mbus Secondary address(Default 00 00) (for SDM230-Mbus only)
2-3	I dL0001	Low bit of Mbus Secondary address(Default 00 01) Example: if the Secondary address high bit is 0000, low bit is 0001, that means the integral Secondary address is 00 00 00 01 (for SDM230-Mbus only)
3	bd 9600	Baud rate for Modbus Default value: 2400bps Range: 1200, 2400, 4800, 9600bps. Baud rate for Mbus: Default value: 2400bps Range:300, 600, 1200, 2400, 4800, 9600bps.
3-1	bd 9600	Press the "Enter" button, the red digit flash. Press the "Scroll" button to change the value. After choosing the new baud rate, the user needs to press the "Enter" button to confirm the setting.
4	Prty N	Parity Default: None Option : None, Even, Odd
4-1	Prty R	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new parity, the user needs to press the "Enter" button to confirm the setting.
5	PLS OUT kWh	Pulse Output 1 Default: kWh Option:kWh / KVArh / Imp. kWh / Exp.kWh / Imp.KVArh / Exp.kVArh
5-1	PLS OUT kWh	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new pulse output option, the user needs to press the "Enter" button to confirm the setting.
6	PLS cSt	Pulse Constant Default: 1000 Option: 1000 / 100 / 10 / 1
6-1	cSt 1000	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new pulse constant option, the user needs to press the "Enter" button to confirm the setting.
7	PLS t	Pulse duration Default: 100ms Option: 200 / 100 / 60ms
7-1	PLSt 200	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new pulse duration option, the user needs to press the "Enter" button to confirm the setting.
8	dIT SEE	Demand Integration Time Default: 15 minutes Option: off(0) / 5 / 10 / 15 / 30 / 60
8-1	dIT 15	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new DIT option, the user needs to press the "Enter" button to confirm the setting.

9	Scrl t	Automatic Scroll Time Interval Default: 0 S Option: 0 ~ 30S
9-1	t 30 S	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new "Scrl" option, the user needs to press the "Enter" button to confirm the setting.
10	LP SEE	Backlit lasting time set-up Default: 60 min Option: 0(off) / 5/ 10/ 20/ 30/ 60 Long press "Enter" button to enter set-up mode.
10-1	LP 60	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new "Scrl" option, the user needs to press the "Enter" button to confirm the setting.
11	clr	Clear Long press "Enter" to enter clear interface.
11-1	MD clr	Clear Max demand of active power Long press "Enter" button to confirm the operation.
12	Σ r kVAh kWh	Clear the resettable energy Long press the Enter button to confirm the operation.
13	SEEPASS	Password Default: 1000
13-1	PAS 1000	Press the "Enter" button, the red part flash. Press the "Scroll" button to change the option. After choosing the new "Scrl" option, the user needs to press the "Enter" button to confirm the setting.

3.Specifications

3.1 General Specifications

Voltage AC (Un)	230V
Voltage Range	176~276V AC
Base Current (Ib/Iref)	10A
Max. Current (Imax)	100A
Min Current (Imin)	0.5A
Starting current	0.4% of Ib/Iref
Power consumption	<2W/10VA
Frequency	50Hz(for MID version) 50Hz(default),60Hz optional
AC voltage withstand	4KV for 1 minute
Impulse voltage withstand	6KV-1.2uS waveform
Over current withstand	30Imax for 0.01s
Pulse 1 output rate	configurable, default 1000/kWh
Pulse 2 output rate	non-configurable,1000/kWh
Display	LCD with backlit
Max. Reading	999999.9kWh

3.2 Accuracy

Voltage	0.5% of range max.
Current	0.5% of nominal
Frequency	0.2% of mid-frequency
Active power	1% of range maximum
Reactive power	1% of range maximum
Apparent power	1% of range maximum
Active energy	Class 1 IEC62053-21
	Class B EN50470-3
Reactive energy	1% of range maximum


3.3 Environment

Operating temperature	-25°C to +55°C
Storage/transportation temperature	-40°C to +70°C
Reference temperature	23°C ± 2°C
Relative humidity	0 to 95%, non-condensing
Installation category	CAT II
Mechanical Environment	M1
Electromagnetic environment	E2
Degree of pollution	2

*Maximum operating and storage temperatures are in the context of typical daily and seasonal variation.

3.4 Pulse Output


The pulse output 1 can be set to generate pulses to represent total kWh, total kVArh, import kWh, export kWh, import kVArh, export kVArh. Constant can be set to 1000/100/10/1 impulse per kWh or kVArh. Pulse width 200/100/60ms.



ATTENTION: Pulse output must be fed as shown in the wiring diagram below. Scrupulously respect polarities and the connection mode. Opto-coupler with potential-free SPST-NO Contact. Contact range: 5~27VDC Max. current Input: 27mA DC.

6.Wiring diagram

6.1 SDM230-V1



3.5 RS485 output for Modbus RTU

*Not for SDM230-Pulse or SDM230-Mbus

The meter provides a RS485 port for remote communication. Modbus RTU is the protocol applied. For Modbus RTU, the following RS485 communication parameters can be configured from the Set-up menu.
Baud rate: 1200, 2400, 4800, 9600 bps
Parity: NONE/EVEN/ODD
Stop bits: 1 or 2
Modbus Address: 1 to 247

3.6 Mbus


*For SDM230-Mbus only

The meter provides a Mbus Port for remote communication. the meter adopts EN1434-3 Mbus communication protocol. The communication parameters can be configured via the SET-UP mode.
Baudrate: 300,600,1200,2400,4800,9600 bps
Parity: NONE/ODD/EVEN
Stop bits: 1 or 2
Primary address: 001~250
Secondary address: 00000001~99999999


3.7 Mechanics

Din rail dimensions	36x99x63 (WxHxD) Per DIN 43880
Mounting Sealing Material	DIN rail 35mm IP51 (indoor) self-extinguishing UL94V-1

4.Dimensions




6.2 SDM230-V2




6.3 Definitions of other terminals


SDM230-2T




SDM230-Modbus/Std



SDM230-Mbus



SDM230-Pulse



Declaration of Conformity(for the MID approved version meter only)

We Zhejiang Eastron Electronic Co.,Ltd.

Declare under our sole responsibility as the manufacturer that the poly phase multifunction electrical energy meter "SDM230 Series" correspond to the production model described in the EU-type examination certificate and to the requirements of the Directive 2014/32/EU EU type examination certificate number 0120/SGS0206. Identification number of the NB0120

Zhejiang Eastron Electronic Co.,Ltd.
Add: No.1369 , Chengnan Rd. Jiaxing,
Zhejiang, China
Tel: 86 573 83698881/83698882
Fax: 86 573 83698883
Email: sales@eastrongroup.com
Web: www.eastrongroup.com



CE RoHS MID